

P270 – PROPOSED LEGAL TEXT

SECTION K: CLASSIFICATION AND REGISTRATION OF METERING SYSTEMS AND BM UNITS (V33.0)

Amend paragraph 1.7.3 as follows:

1.7.3 For the avoidance of doubt, a Line Loss Factor relating to a Metering System at a Boundary Point or a Remote Grid Supply Point on a Distribution System where such Distribution System is indirectly connected to the Transmission System (or, in respect of a Remote Grid Supply Point, the Contiguous Transmission System) must, when applied to data relating to such Metering System, convert such data into a value at the Transmission System Boundary (or, in respect of a Remote Grid Supply Point, the Contiguous Transmission System Boundary), with such Line Loss Factor to take into account distribution losses both on:

- (a) that Distribution System; and
- (b) on the Distribution System by which it is indirectly connected to the Transmission System (or, in respect of a Remote Grid Supply Point, the Contiguous Transmission System).

SECTION X: DEFINITIONS AND INTERPRETATION

ANNEX X-1: GENERAL GLOSSARY (V51.0)

Amend Section X by inserting the following definitions in alphabetical order into Annex X – 1 General Glossary:

<u>"Contiguous Transmission System":</u>	<u>means any part of the Transmission System that is connected by transmission assets to two or more GSP Groups;</u>
<u>"Contiguous Transmission System Boundary":</u>	<u>means the boundary between the Contiguous Transmission System and all Plant or Apparatus (including Distribution Systems and other directly connected Plant and Apparatus) connected to the Contiguous Transmission System;</u>
<u>"Remote Grid Supply Point":</u>	<u>means a Grid Supply Point which is not connected to the Contiguous Transmission System;</u>

ANNEX X-2: TECHNICAL GLOSSARY (V31.0)

Amend Section X by amending the following definition in Annex X – 2 Technical Glossary:

Line Loss Factor			Means a multiplier which: <u>(i)</u> -when applied to data from a CVA Metering System connected to a Boundary Point on a Distribution System, converts such data into an equivalent value at the Transmission System
------------------	--	--	---

			<p>Boundary; <u>or</u></p> <p><u>(ii) when applied to data from a CVA Metering System connected to a Remote Grid Supply Point, converts such data into an equivalent value at the Contiguous Transmission System Boundary.</u></p>
--	--	--	--