

CDCA Service Description version 15 Red line Extract

8. COLLECTION OF METERING SYSTEM DATA

- 8.5 make provisions to collect the Meter period data manually, by visit to site, where collection of Meter period data via a communication link is not possible. Where the Meters are located Offshore at an Offshore Power Park Module, make arrangements, as agreed with the Registrant, to collect the Meter period data manually.

12. METER ADVANCE RECONCILIATIONS

The CDCA shall:-

- 12.1. produce a Meter Reading Schedule for each Metering System on an annual basis, at least three months ahead of the commencement of that Meter Reading Schedule and forward to the Registrant of the Metering System and the relevant MOA;
- 12.2. schedule Meter reading visits as follows:
- at least every 12 months for Meters with integral Outstations that provide a cumulative reading of the prime Meter register equivalent to the total consumption or production of that Meter;
 - at least every 6 months for other Meters with integral Outstations; ~~and~~
 - at least every 3 months for Meters with external Outstations; and
 - for Meters, with external Outstations, located Offshore at Offshore Power Park Modules:
 - within 3 Months of commencement of the Meter Reading Schedule for the first Meter reading visit; and
 - at least every 12 months for each Meter reading visit thereafter.
- 12.3. keep a list of which Meters qualify for which frequency of visit;:-
- 12.4. ensure, or procure that Meter reading is carried out on the registers of all physical Meters recording active energy and the active energy registers of associated data collector outstations, where applicable, which provide Meter period data collected by the CDCA for Settlement purposes, in accordance with Section 12.2;