

CP1296 ATTACHMENT - REDLINE CHANGES TO BSCP601 V10.1 CONFORMED – SEE BELOW:

Section 1 to 3.4.5 will not be impacted by CP1296

3.4.6 Measured Quantities {4.1.1}

The following tests shall be performed to establish the measured quantities:

(a)	establish the number and type of Measured Quantities available on the Meter;	001
(b)	if more than one Measured Quantity configuration is available, list all configurations;	002
(c)	confirm that a cumulative register display is available for each Measured Quantity (see also 3.4.12);	003
(d)	Import Active Energy is measured in kWh; <u>Import Reactive Energy is measured in kvarh (CoP 5 only)</u>	004
(e)	Export Active Energy is measured in kWh; <u>Export Reactive Energy is measured in kvarh (CoP 5 only);</u> and	005
(f)	confirm that Measured Quantities are available in both kilo and Mega values. (CoPs 1 and 2 only)	006

3.4.7 Demand Values {4.1.2}

The following test shall be performed to confirm that Demand values are provided:

(a)	confirm that a kW value is provided for each Demand Period for each Active Energy Measured Quantity; <u>and</u> <u>kvarh value is provided for each Reactive Energy Measured Quantity (CoP 5 only)</u>	007
(b)	where Import and Export values are provided confirm that each value is gross and recorded separately. (Applies to CoP 5 3 and 10 only);and	008
(c)	confirm that Demand values are available in both kilo and Mega values. (CoPs 1 and 2 only)	009

There will be no further changes to BSCP601 as part of CP1296.