

CP1297 ATTACHMENT - REDLINE CHANGES TO COP10 ISSUE 1 V1.0

SECTION 1 to 3 WILL NOT BE IMPACTED BY CP1297.

4. MEASUREMENT CRITERIA

4.1. Measured Quantities and Demand Values

4.1.1. Measured Quantities

For each separate circuit the following energy measurements shall be provided:-

- (i) Import kWh₋*
- (ii) Export kWh₋*
- (iii) Import kVA_{varh}*
- (iv) Export kVA_{varh}*

While Active Energy values are a Settlement requirement the Reactive Energy values are not but are likely to be required by Licensed Distribution System Operators (LDSO).

4.1.2. Demand Values

For each Demand Period for each circuit the following Demand Values shall be provided:-

- (i) Import kW₋*
- (ii) Export kW₋*
- (iii) Import kvar
- (iv) Export kvar

* Import and/or Export metering need only be installed where a Party requires this measurement to meet system or plant conditions.

Where Import and Export metering is installed gross Import and gross Export Active Energy shall be recorded separately for Settlements.

While Active Energy values are a Settlement requirement the Reactive Energy values are not but are likely to be required by LDSO.

SECTION 4.2 - END OF DOCUMENT WILL NOT BE IMPACTED BY CP1297.