

<b>Change Proposal – F40/01</b>	<b>CP No: 1064</b>  <b>Version No: 1.0</b>
<b>Title:</b> Flows to be sent on a Non-Half Hourly change of Energisation Status	
<b>Description of Problem/Issue</b>  It has been identified that during the drafting of BSCP514 ‘SVA Meter Operation for Metering Systems Registered in SMRS’, the instances of sending the D0010 ‘Meter Readings’ alongside the D0139 ‘Confirmation or Rejection of Energisation Status Change’ in the energisation and de-energisation processes in the Non-Half Hourly (NHH) market were inadvertently removed. When consequential changes for BSCP514 were applied to BSCP504 ‘Non-Half Hourly Data Collection for Metering Systems Registered in SMRS’, the requirement was also removed from BSCP504. The sending of the D0010 in parallel to the D0139 in the NHH market should not have been removed and should therefore be reinstated.	
<b>Proposed Solution(s)</b> <i>(mandatory by originator)</i>  The following changes are required to BSCP504 and BSCP514: <ul style="list-style-type: none"> <li>▪ BSCP504, 3.3.3.1 ‘Energise a SVA Metering system’ and 3.3.4.1 ‘De-energise a SVA Metering System’ – Add the D0010 ‘Meter Readings’ to the Information required box.</li> <li>▪ BSCP514, 6.3.1.4 ‘Energise a SVA Metering system’ and 6.3.2.4 ‘De-energise a SVA Metering System’ – Add the D0010 ‘Meter Readings’ to the Information required box.</li> </ul> These changes will mean that the D0010 ‘Meter Readings’ can be sent alongside the D0139 ‘Confirmation or Rejection of Energisation Status Change’ in the NHH market.  The reference numbers are taken from BSCP504 v10.0 and BSCP514 v3.0.	
<b>Justification for Change</b> <i>(mandatory by originator)</i>  This change will bring the documents back in line with Industry practise and will correct a change that was inadvertently made with the introduction of BSCP514.	
<b>Configurable Items Potentially Affected by Proposed Solution(s)</b>  BSCP504 ‘Non-Half Hourly Data Collection for Metering systems Registered in SMRS’ BSCP514 ‘SVA Meter Operations for Metering Systems Registered in SMRS’	
<b>Impact on Core Industry Documents</b>  None	
<b>Related Changes and/or Projects</b>  None	

## Change Proposal – F40/01

CP No: 1064

*Version No: 1.0*

**Requested Implementation Date:** The next appropriate release

**Reason:**

**Agreed Release/Implementation Date** *(mandatory by BSCCo)*

***Originator's Details:***

***BCA Name*** *Katie Key*

***Organisation*** *ELEXON*

***Email Address*** *Katie-ann.key@elexon.co.uk*

***Date*** *28/6/04*

Attachments: N