

BSCP 504, Footnote 75 to be amended as follows:

The NHHDC will inform the Supplier if the SVA MS equipment is inadequate or that insufficient data about a SVA MS is available. The Supplier will investigate the situation and ensure that the SVA MS and the information provided are adequate. Where a SVA MS is de-energised ~~and no remote communications exist~~, the NHHDC shall make visits to the site concerned every 12 months.

PSL 120 to be amended as follows:

**1.5.2 De-energised Meters**

1.5.2.1 Where the Non Half Hourly Data Collector has been informed by its Associated Supplier or the relevant Associated Meter Operator Agent that a SVA Metering System has been de-energised ~~and no remote reading communications equipment is functioning~~, the Non Half Hourly Data Collector shall make visits to the site concerned at least once every 12 months, the first such period beginning with the date on which the Non Half Hourly Data Collector is so informed.