



CP1200 'Removal of the Requirement for Proving Test Out of Timescale Escalation Report'

Redlined text based on BSCP502 'Half Hourly Data Collection for SVA Metering Systems Registered in SMRS' v13.0

Amend step table 3.5.6 as follows:

3.5.6 HHDC Reports that no Proving Test has been Initiated.

REF	WHEN	ACTION	FROM	TO	INFORMATION REQUIRED	METHOD
3.5.6.1	As required in accordance with Appendix 4.6.	Report that no proving test has been initiated.	HHDC.	Supplier, MOA, BSCCo.	P0212 Notification of Failure to Carry Out Proving Test.	Electronic or other method, as agreed.
3.5.6.2	Following 3.5.6.1	Agree and confirm timescales in which to complete the proving test.	Supplier.	MOA.	Proceed to 3.5.1, 3.5.2, 3.5.3 or 3.5.4.	Telephone, Fax, Email

Amend text in section 4.6.4 Reporting as follows:

4.6.4 Reporting.

The MOA shall report both successful and non-successful proving tests to relevant parties.

~~If the HHDC receives the MTD, via receipt of the D0268 Half Hourly Meter Technical Details and knows that a proving test should have been performed based on the circumstances defined in 4.6.1 but no successful proving test has been initiated by the MOA within the timescales in 4.6.5, the HHDC shall report this to the MOA, the Supplier and BSCCo. The MOA shall then be required to perform a proving test within the timescales agreed with the Supplier.~~