



Redlined text for CP1464 'Requiring HH consumption data to be processed to appropriate precision'

This CP proposes changes to Section 4 'Appendices' (specifically to add a new paragraph 4.1A at the beginning of Section 4) and section 1.6.1 'Acronyms'.

We have redlined these changes against Version 25.0

There is no impact on any other part of this document for this CP.

1.6.1 Acronyms

Wh Watt hour

4. Appendices

4.1A HH Meter Data Precision

Where Metering Systems can provide HH Meter Period data to the nearest Wh the HHDC or Supplier shall process the data to that granularity and provide the Meter Period data, to three decimal places, on the appropriate data flows that support MSID level data to that granularity, to the relevant party. Where Metering Systems cannot provide data to the nearest Wh the HHDC or Supplier shall populate the additional decimal places for the Metered Period Value or Meter Period Consumption within the HH data flows with zeros.