

## DRAFT LEGAL TEXT FOR PROPOSED MODIFICATION P356

### SECTION R: COLLECTION AND AGGREGATION OF METER DATA FROM CVA METERING SYSTEMS (V14.0)

#### 7. INTERCONNECTOR BM UNIT METERED VOLUMES

##### 7.1 General

*Amend paragraph 7.1.3 to read as follows:*

7.1.3 For the purposes of this paragraph 7:

- (a) the "**Interconnector Scheduled Transfer**" for each Interconnector in relation to a Settlement Period is the Active Energy flow, scheduled for all Interconnector Users (and not exceeding the physical capability of the Interconnector as from time to time determined under the relevant Interconnection Agreements), across the Interconnector (as a whole), as established pursuant to the relevant Interconnection Agreements between the Interconnected System Operator and the Externally Interconnected System Operator, stated as at the Transmission System Boundary, in the form of a schedule expressed as MW values for the spot times at the start and end of, and other spot times within, the Settlement Period;
- (b) after Gate Closure in relation to any Settlement Period, the Interconnector Scheduled Transfer is to be adjusted to reflect:
  - (i) any failure or derating of the physical capability of the Interconnector (as determined under the relevant Interconnection Agreements), and any subsequent uprating of the physical capability of the Interconnector provided that the uprated capability does not exceed the Interconnector Scheduled Transfer established at Gate Closure;
  - (ii) the acceptance by the Transmission Company of any Offer or Bid submitted by an Interconnector User in respect of an Interconnector BM Unit; ~~or~~
  - (iii) any event occurring in relation to an External System, to the extent so provided in the relevant Interconnection Agreements, as notified to the Interconnector Administrator; or
  - (iv) in relation to an Interconnector, the results of Single Intraday Coupling provided that such adjustment shall be made by no later than 10 minutes following the Intraday Cross-Zonal Gate Closure Time for the relevant Settlement Period.but shall not otherwise be adjusted;
- (c) the "**final**" Interconnector Scheduled Transfer in relation to a Settlement Period is the Interconnector Scheduled Transfer prevailing at the end of that Settlement Period;
- (d) for each Interconnector BM Unit:

- (i) the "**Expected Transfer**" in relation to a Settlement Period is a schedule of expected Active Energy flows, stated as at the Transmission System Boundary, expressed as MW values for the spot times at the start and end of, and other spot times within, the Settlement Period;
  - (ii) in the case of a Production BM Unit, the Expected Transfer shall relate only to Exports;
  - (iii) in the case of a Consumption BM Unit, the Expected Transfer shall relate only to Imports.
- (e) for the purposes of an Interconnector Scheduled Transfer and an Expected Transfer, MW values are to be specified at particular spot times during (and including the start and end of) the relevant Settlement Period, and MW values at other spot times shall be established by linear interpolation.

### 7.3 Adjustments after Gate Closure

*Amend paragraph 7.3.1 to read as follows:*

7.3.1 Following Gate Closure and until the end of the Settlement Period:

- (a) promptly upon any revision thereto, the Interconnected System Operator shall send or procure that there is sent to the Interconnector Administrator the revised Interconnector Scheduled Transfer;
- (b) where the Interconnector Administrator is so notified of a revision to the Interconnector Scheduled Transfer, the Interconnector Administrator shall adjust the Expected Transfer(s) accordingly and consistent with paragraph 7.1.4, provided that:
  - (i) in the case of a revision to the Interconnector Scheduled Transfer under paragraph 7.1.3(b)(ii), only the Expected Transfer of the Interconnector User which submitted the Bid or Offer therein referred to shall be so adjusted;
  - (ii) in the case of a revision to the Interconnector Scheduled Transfer under paragraph 7.1.3(b)(iii), the Expected Transfer to be adjusted shall be that of the Interconnector User as determined and notified to the Interconnector Administrator in accordance with the applicable provisions of the relevant Interconnection Agreement;
  - (iii) in the case of a revision to the Interconnector Scheduled Transfer under paragraph 7.1.3(b)(iv), the Expected Transfer to be adjusted to reflect the results of Single Intraday Coupling shall be that of the Interconnector User as determined and notified to the Interconnector Administrator in accordance with the applicable provisions of the relevant Interconnection Agreement;
- (c) no adjustment shall be made to Expected Transfers other than pursuant to paragraph (b).

## ANNEX X-1: GENERAL GLOSSARY (V78.0)

*Insert the following new definitions in alphabetical order:*

**"Intraday Cross-Zonal Gate Closure Time":**

has the meaning given to that term in Commission Regulation (EU) 2015/1222 of 24 July 2015 establishing a guideline on capacity allocation and congestion management (CACM);

**"Single Intraday Coupling":**

has the meaning given to that term in Commission Regulation (EU) 2015/1222 of 24 July 2015 establishing a guideline on capacity allocation and congestion management (CACM);