

BSCP32/4.1 Application for a Metering Dispensation

Part A – Applicant Details

To: BSCCo	Date Sent: _25 July 2017____
From: Requesting Applicant Details	
Name of Sender:	Paul McGimpsey_____
Contact email address:	
Contact Tel. No.	Contact Fax. No._____
Name of Applicant Company: SP Manweb plc	
Address: 3 Prenton Way	
Prenton	
Birkenhead	
Post Code:___CH43 3ET_____	
Our Ref: _____	
Name of Authorised Signatory: _____	
Authorised Signature:	Password:
_____	_____

Confidentiality:

Does any part of this application form contain confidential information?

Request for Confidentiality ~~YES~~/NO*

**Delete as applicable*

If 'YES', please state the parts of the application form that are considered confidential, including justification below. Information that is considered confidential:

Reasons for requesting confidentiality:

.....
number, site name, expiry date (if any) and BSC Panel determinations will routinely be made available in the public domain unless the applicant informs BSCCo otherwise at the time of application

BSCP32/4.1 Application for a Metering Dispensation (Cont.)**Part B - Affected Party Details**Number of Affected parties _____¹

Contact Name at Affected party:	
Contact email address:	
Contact Tel. No.	Contact Tel. No.
Company Name of Affected party:	
Address:	
Post Code:	

Contact Name at Affected party:	
Contact email address:	
Contact Tel. No:	Contact Tel. No.
Company Name of Affected party:	
Address:	
Post Code:	

¹ For more than one Affected party, Part B should be completed for each, using additional copies of Part B as required.

Contact Name at Affected party:	
Contact email address:	
Contact Tel. No.	Contact Tel. No.
Company Name of Affected party:	
Address:	
Post Code:	

BSCP32/4.1 Application for a Metering Dispensation (Cont.)

Part C – Reason for Application

If the application is an extension or update for an existing Metering Dispensation, enter existing ref: D/.....

Site Specific / Generic* *Delete as applicable.

Describe why you require a Metering Dispensation. Include any steps you propose to limit the impact on Settlement and other Registrants:

Section L3.2 'Compliance with Codes of Practice' requires Metering Equipment to comply with the version of the relevant Code of Practice (CoP) that is applicable to that item of Metering Equipment at the time that the Metering System (comprising that Metering Equipment) is first registered for Settlement purposes.

The current version of CoP1 (Issue 2, version 11) requires voltage transformers to comply with IEC standard 60044-2². However in 2011 this standard was replaced with IEC 61869-3³. CoP1 therefore needs to be updated to ensure it references the latest voltage transformer standard. Whilst ELEXON progress this change we require a lifetime generic Metering Dispensation to ensure that the voltage transformers we purchased, which were tested to the latest voltage transformer standard (IEC 61869-3), can be installed and registered against the current version of CoP1.

There should be no impact on Settlements (or other Registrants) by using voltage transformers tested to the latest standard.

Period of Metering Dispensation required

Lifetime / Temporary* *Delete as applicable.

If temporary, indicate for how long the Metering Dispensation is required.	
--	--

Provide justified reasoning for the period of Metering Dispensation requested in the box below:

Rationale for duration of Metering Dispensation:

We require a lifetime generic Metering Dispensation from the current version of CoP1 (Issue

² 'Instrument transformers - Part 2 : Inductive voltage transformers'

³ 'Instrument transformers – Part 3: Additional requirements for inductive voltage transformers'

2 version 11) so that any voltage transformers we (or other BSC Parties) install and register as a Metering System, prior to ELEXON implementing the necessary update to CoP1 to reflect the latest standard (IEC 61869-3), are subject to a Metering Dispensation for their lifetime.

A condition could be attached to this Metering Dispensation so that it can only be used until CoP1 is updated with IEC 61869-3.

Materiality

Please complete the following:

What is the cost of providing compliant Metering Equipment?	What does this cost entail?
Several thousand pounds.	The voltage transformers would need to be returned to the factory for possible retesting against the superseded standard (IEC 60044-2) and rebadged as compliant with it.
What is the cost of the proposed solution?	What does this cost entail?
Zero.	n/a
What is the impact to Settlement of your proposed solution?	Why?
None	We believe that there are no material differences in the superseded (IEC 60044-2) and current standard (IEC 61869-3) that would have any impact on Settlements.
What is the impact to other Registrants of your proposed solution?	Why?
None	We believe that there are no material differences in the superseded (IEC 60044-2) and current standard (IEC 61869-3) that would have any impact on Settlements and therefore other Registrants.

Site Details (for Site Specific Metering Dispensation)

Site Name:	
Site Address:	
MSID(s):	
Registered in: CMRS / SMRS*: *Delete as applicable.	
For SMRS, please advise of SMRA in space provided.	

Manufacturer Details (for Generic Metering Dispensation)

Manufacturer Name:	
Metering Equipment Details:	

BSCP32/4.1 Application for a Metering Dispensation (Cont.)

Part D - Technical Details**Code of Practice details**

Metering Dispensation against Code of Practice*	
Issue of Code of Practice*:	
Capacity of Metering Circuits/Site Maximum Demand (MW/MVA):	
(Proposed) Commissioning Date of Metering:	
Accuracy at Defined Metering Point:	
Accuracy of Proposed Solution (including loss adjustments):	
Outstanding non-compliances on Metering Systems:	
Deviations from the Code of Practice (reference to appropriate clause):	

* insert Code of Practice number and issue

Any Other Technical Information

--

Declaration

We declare that other than as set out above we are in all other respects, in compliance with the requirements of the relevant Code of Practice and the BSC. A schematic is attached to this application for clarification of the metering points involved.

Signature: *Date:* 25th July 2017

Password:

Duly authorised for and on behalf of Applicant Company

Confirmation of Receipt and Reference

The BSCCo acknowledges receipt of this document and has assigned the reference number as indicated on the first page.

Signature: M Smith..... *Date:* 26 July 2017

Duly authorised for and on behalf of the BSCCo