

Balancing and Settlement Code

BSC PROCEDURE

Metering Dispensations

BSCP32

~~Version 10.0~~

Date: ~~2 November 2017~~

BSC PROCEDURE 32**relating to****METERING DISPENSATIONS**

1. Reference is made to the Balancing and Settlement Code and, in particular, to the definition of "BSC Procedure" in Section X, Annex X-1 thereof.
2. This is BSC Procedure 32, ~~Version 10.0~~ relating to Metering Dispensations.
3. This BSC Procedure is effective from ~~2 November 2017~~
4. This BSC Procedure has been approved by the Panel.

DRAFT

Intellectual Property Rights, Copyright and Disclaimer

The copyright and other intellectual property rights in this document are vested in ELEXON or appear with the consent of the copyright owner. These materials are made available for you for the purposes of your participation in the electricity industry. If you have an interest in the electricity industry, you may view, download, copy, distribute, modify, transmit, publish, sell or create derivative works (in whatever format) from this document or in other cases use for personal academic or other non-commercial purposes. All copyright and other proprietary notices contained in the document must be retained on any copy you make.

All other rights of the copyright owner not expressly dealt with above are reserved.

No representation, warranty or guarantee is made that the information in this document is accurate or complete. While care is taken in the collection and provision of this information, ELEXON Limited shall not be liable for any errors, omissions, misstatements or mistakes in any information or damages resulting from the use of this information or action taken in reliance on it.

AMENDMENT RECORD

Version	Date	Description of Changes	Changes Included	Mods/ Panel/ Committee Refs
1.0	Code Effective Date	Designated version	n/a	n/a
2.0	14/12/00	Work outstanding at Go Active resolution of inconsistencies inclusion of consultation comments	227	09/006
3.0	13/08/02	Change Proposal for BSC Systems Release 2	CP614	ISG16/166
4.0	24/06/03	Change Proposals for CVA June 03 Release	CP821	ISG21/226
5.0	30/06/04	Change Proposals for the CVA Programme June 04 Release	CP854	ISG/40/003 SVG/40/004
6.0	23/02/05	CVA Programme February 05 Release	BETTA 6.3, P159	78/007
7.0	02/11/05	CVA Programme November 05 Release	CP1108	ISG/52/003
8.0	23/02/06	Change Proposals for the February 06 Release	CP1112	ISG/55/002 SVG/55/002
9.0	05/11/15	November 2015 Release	CP1442	ISG171/01 SVG174/06
10.0	02/11/17	November 2017 Release	CP1485	ISG194/06 SVG196/06
<u>10.2</u>	<u>29/03/19</u>	<u>29 March 2019 Standalone Release</u>	<u>P369</u>	<u>TBC</u>

CONTENTS

1	INTRODUCTION	6
1.1	Purpose and Scope of the Procedure	6
1.2	Main Users of the Procedure and their Responsibilities	6
1.3	Balancing and Settlement Code Provision	6
1.5	Metering Dispensation Applications	7
1.6	Register of Metering Dispensations	8
1.7	Classification of Metering Dispensations	8
1.8	Notification of CVA Metering Dispensations	8
1.9	Factors Affecting Metering Dispensations	8
2	ACRONYMS AND DEFINITIONS	9
[P369]2.1	List of Acronyms	9
[P369]2.2	LIST OF DEFINITIONS	10
3	INTERFACE AND TIMETABLE INFORMATION	11
3.1	Application for Metering Dispensation (Site Specific, Generic)	11
2	Withdrawal of a Proposed or Approved Metering Dispensation.	13
3.3	Validation of Power Transformer and Cable/Line Loss Adjustments to be applied to a Metering System	15
4	APPENDICES	20
4.1	Application for a Metering Dispensation	20
4.2	Form BSCP32/4.2 is no longer used.	20
4.3	Form BSCP32/4.3 is no longer used.	20
4.4	Notification of Panel Ruling on Metering Dispensation Application	20
4.5	Application to Withdraw a Metering Dispensation	20
4.6	Form BSCP32/4.6 is no longer used.	20
4.7	Forms	20
BSCP32/4.1	Application for a Metering Dispensation	21
1	INTRODUCTION	5
1.1	Purpose and Scope of the Procedure	5
1.2	Main Users of the Procedure and their Responsibilities	5
1.3	Balancing and Settlement Code Provision	5
1.5	Metering Dispensation Applications	6
1.6	Register of Metering Dispensations	7
1.7	Classification of Metering Dispensations	7
1.8	Notification of CVA Metering Dispensations	7
1.9	Factors Affecting Metering Dispensations	7
2	ACRONYMS AND DEFINITIONS	8

2.1	List of Acronyms	8
2.2	List of Definitions	9
3	INTERFACE AND TIMETABLE INFORMATION	10
3.1	Application for Metering Dispensation (Site Specific, Generic)	10
3.2	Withdrawal of a Proposed or Approved Metering Dispensation.	13
3.3	Validation of Power Transformer and Cable/Line Loss Adjustments to be applied to a Metering System	14
4	APPENDICES	19
4.1	Application for a Metering Dispensation	19
4.2	Form BSCP32/4.2 is no longer used.	19
4.3	Form BSCP32/4.3 is no longer used.	19
4.4	Notification of Panel Ruling on Metering Dispensation Application	19
4.5	Application to Withdraw a Metering Dispensation	19
4.6	Form BSCP32/4.6 is no longer used.	19
4.7	Forms	19
BSCP32/4.1	Application for a Metering Dispensation	20

DRAFT

1 Introduction

1.1 Purpose and Scope of the Procedure

Metering Equipment shall, save as otherwise provided in the Code, comply with the minimum requirements referred to or set out in the relevant Code of Practice. If for practical and/or financial reasons any Metering Equipment or Metering System comprised therein does not meet all or any of the requirements referred to, or set out in the relevant Code of Practice, the Metering Equipment or Metering System may be the subject of an application for a Metering Dispensation from that relevant Code of Practice in accordance with this BSCP32 and Section L of the Code.

The relevant Code of Practice in respect of any Metering Equipment comprising any Metering System shall be determined by reference to Section L of the Code.

This procedure outlines the responsibilities with regard to processing applications for Metering Dispensations, and outlines the timeframes involved. It also details the information required for submission with an application, notifications to Parties and records to be maintained in respect of all Metering Dispensations.

This procedure also sets out the criteria to be used by the Panel in considering a Metering Dispensation application and the requirement of the Applicant to declare his intended course of action, in writing to the Panel, within a specified timescale following approval of the application.

Metering Dispensations may be granted on such conditions (if any) as the Panel may deem fit.

This procedure also outlines the responsibilities with regard to validating electrical loss adjustments, where proposed under a site specific Metering Dispensation application or, where proposed when the relevant Code of Practice does not require a Metering Dispensation. It also outlines the timeframes involved. Guidance on standard methods for calculating and compensating for power transformer and cable (or line) losses can be found on the BSC Website.

1.2 Main Users of the Procedure and their Responsibilities

This BSCP is to be used by the following:

- The Registrant or intended Registrant of the Metering Equipment.
- The Applicant(s) for generic Metering Dispensations.
- The BSCCo, for processing applications and maintaining records of all Metering Dispensations.
- The Panel, for endorsing or rejecting Metering Dispensation applications.

1.3 Balancing and Settlement Code Provision

This BSCP should be read in conjunction with the Code and in particular Section L.

This BSCP has been produced in accordance with the provisions of the Code. In the event of an inconsistency between the provisions of this BSCP and the Code, the provisions of the Code shall prevail.

1.4 Associated BSC Procedures

This procedure interfaces with the following BSCPs:

BSCP20	Registration of Metering Systems for CVA
BSCP27	Technical Assurance of Half Hourly Metering Systems for Settlement Purposes
BSCP38	Authorisations
BSCP501	Registration of Metering System for Supplier Volume Allocation
BSCP514	SVA Meter Operations for Metering Systems Registered in SMRS

1.5 Metering Dispensation Applications

The Registrant of a Metering System may apply for Metering Dispensations that apply specifically to the Metering Equipment in that Metering System. In addition the Panel may, on its own initiative or upon the application of a Party, establish Metering Dispensations that apply to any item of Metering Equipment.

When making any application, the Applicant must allow sufficient time for the approval process to be completed prior to the installation / commissioning of the associated Metering System. Applicants may request confidentiality via the application form (BSCP32/4.1). Where the Applicant requests confidentiality, it must be clearly stated in the application the information that is considered confidential and the reasons why confidentiality is requested. The BSCCo will make available all information necessary for the BSC Panel or its delegated Panel Committees to perform their duties in the technical assessment of the application. This may include any information considered confidential by the Applicant. In all cases, the site name, Metering Dispensation number, expiry date (if time limited) and BSC Panel determinations will be made available in the public domain, unless the Applicant specifically agrees otherwise with the BSCCo.

Applications for the extension of time limited Metering Dispensations should be submitted as soon as the Applicant becomes aware that an extension may be required and in any event prior to the termination of the relevant Metering Dispensation. Consideration should be given to the timescales required in order for the Metering Dispensation application to be processed and decided on by the relevant Panel Committee. Failure to do so could result in the Metering System being non-compliant with the BSC and hence be subject to escalation to the BSC Panel.

In all cases, where the BSCP32/4.1 application form is not adequately or properly completed, the BSCCo reserves the right to reject the application at the submission stage and request such information to be provided before the application is progressed further.

1.6 Register of Metering Dispensations

The BSCCo shall record the progress of such applications and shall provide the appropriate levels of security for both access to and modification of the contents of such register. The BSCCo shall provide such reports from the Metering Dispensation register as the Panel may require. The BSCCo will provide the TAA with duplicate copies of all existing Metering Dispensations. The BSCCo will be responsible for the operation and maintenance of the Metering Dispensation register.

1.7 Classification of Metering Dispensations

Metering Dispensations are classified against a number of criteria. Each Metering Dispensation will have an associated term ('Temporary' or 'Lifetime') and location ('site specific' or 'generic'). Modifications to or extensions of existing Metering Dispensations should be identified as Updates. The Panel may impose conditions on any Metering Dispensations granted. Generic Metering Dispensations apply to specific items of Metering Equipment which may be used to form any number of Metering Systems, subject to the conditions of that Metering Dispensation.

1.8 Notification of CVA Metering Dispensations

The BSCCo will notify the Party concerned of the existence of any valid CVA Metering Dispensations during the registration process. In addition, the BSCCo will publish and maintain a list of all generic Metering Dispensations on the BSC Website.

1.9 Factors Affecting Metering Dispensations

The Panel shall, in considering an application, take into account location, accuracy, functionality of the proposed Metering Equipment and such other factors as they may consider appropriate in relation to the requirements of the relevant Code of Practice.

If it is shown that the Applicant failed to seek the views of any Affected party then any Metering Dispensation agreed may be rendered void. Where the Applicant fails to receive any response from an Affected party, provided the Applicant can prove that it has taken reasonable steps to ensure delivery of notification of its application this shall be sufficient evidence of such notification.

If the Panel believe at any time that relevant circumstances have changed they may withdraw or amend a Metering Dispensation.

If

- (i) a Metering Dispensation is rendered void; or
- (ii) a Metering Dispensation has been agreed for a limited period and such periods have expired; or
- (iii) a Metering Dispensation has been agreed on conditions that certain circumstances will subsist and any of such circumstances shall cease to apply,

then the Applicant may submit a further application in respect of the subject matter of such Metering Dispensation providing that there has not been any change to the Metering Equipment or Metering System since the original application was made. Otherwise a new application for a Metering Dispensation shall be submitted.

Holders of time limited Metering Dispensations should, before the expiry date of the Metering Dispensation, have carried out one of the following actions:

- (iv) Withdrawn the Metering Dispensation; or
- (v) Given written confirmation of compliance to the BSCCo; or
- (vi) Applied for an extension to the Metering Dispensation.

The Panel may instruct the TAA to carry out a targeted visit at any time, in accordance with BSCP27.

2 Acronyms and Definitions

P369 2.1 List of Acronyms

The following is a list of acronyms used in BSCP32:

AMP	Actual Metering Point
BSCP	Balancing and Settlement Code Procedure
BSCCo	Balancing and Settlement Code Company
CMRS	Central Meter Registration Service
CoBO	Change of BM Unit Ownership
CoP	Code of Practice
DMP	Defined Metering Point
EFD	Effective From Date
ELVA	Electrical Loss Validation Agent
LDSO	Licensed Distribution System Operator
<u>NETSO</u>	<u>National Electricity Transmission System Operator as the holder of the Transmission Licence and any reference to "NETSO", "NGESO", "National Grid Company" or "NGC" in the Code or any Code Subsidiary Document shall have the same meaning.</u>
SMRA	Supplier Meter Registration Agent
SMRS	Supplier Meter Registration Service
TAA	Technical Assurance Agent
TC	Transmission Company
WD	Working Day

[P369]2.2 List of Definitions

Actual Metering Point	The physical location at which electricity is metered.
Affected parties	<p>For site specific Metering Dispensations, Affected parties may include: customers; TCNETSO; LDSOs; and any Party other than the Registrant responsible for Aggregation Rules relating to such Metering Equipment.</p> <p>Where the Metering System has not been registered at the time of application, Affected parties include all BSC Parties.</p> <p>For generic Metering Dispensations, Affected parties include all BSC Parties.</p>
Appropriate parties	Any person(s) that the BSCCo or the Panel considers appropriate for consultation. This may include independent experts such as the Metering Dispensation Review Group (MDRG).
Defined Metering Point	Defined Metering Point means the physical location at which the overall accuracy requirements as stated in the relevant Code of Practice are to be met. The Defined Metering Points are identified in the Codes of Practice and relate to Boundary Points and System Connection Points.
Electrical Loss Validation Agent	The agent who validates the accuracy of electrical loss calculations.

Other terms are defined in the Code.

3 Interface and Timetable Information

3.1 Application for Metering Dispensation (Site Specific, Generic)

REF	WHEN	ACTION	FROM	TO	INPUT INFORMATION REQUIRED	MEDIUM
3.1.1	Where appropriate, but before submission of application	<p>Notify and seek endorsement from all Affected parties of intention to apply for a Metering Dispensation from relevant Code of Practice</p> <p>For a site specific Metering Dispensation application where the AMP is not at the DMP and the Registrant needs/wishes to apply electrical loss adjustments to the Metering System see Section 3.3</p>	Applicant	Affected parties	Details of site involved and Metering Dispensation being applied for	Fax / Post / Email
3.1.2	As required	Submit application requesting a Metering Dispensation	Applicant	BSCCo	<p>BSCP32/4.1, Application for a Metering Dispensation</p> <p>For a site specific Metering Dispensation application where the AMP is not at the DMP, include the proposed electrical loss adjustments and information on the power transformer and/or cable/line between the AMP and the DMP to enable these loss adjustments to be validated¹.</p>	Fax / Post / Email

¹ Where the Applicant believes that electrical loss adjustments are not necessary, they should provide suitable justification, including calculations to prove this.

REF	WHEN	ACTION	FROM	TO	INPUT INFORMATION REQUIRED	MEDIUM
					<p>Where appropriate include letter of endorsement from Affected parties.</p> <p>Application forms must be signed by a Category R Authorised Person as registered under BSCP38, or include their password and be sent from the Authorised Person's email address.</p> <p>Please note that all fields must be filled out in form BSCP32/4.1, or the application will not be progressed. Please see the guidance note on the BSCCo website for details on how to fill out form BSCP32/4.1.</p>	
3.1.3	Within 2 WD of 3.1.2	<p>Acknowledge receipt of application</p> <p>Check application for validity and completeness</p> <p>Issue reference number</p> <p>Record application and reference number in register</p>	BSCCo	Applicant	BSCP32/4.1 Application for a Metering Dispensation	Fax / Post / Email
3.1.4	Within 5 WD of 3.1.3 where appropriate	Where additional information or clarifications are required for a determination to be reached, request such information from the Applicant.	BSCCo	Applicant	Request for specific information	Fax / Post / Email
3.1.5	As required	If request for more information received, provide requested information as agreed between the BSCCo and the Applicant.	Applicant	BSCCo	Requested information	Fax / Post / Email
3.1.6	Within 2 WD of 3.1.3 or 3.1.5 (as appropriate)	Notify Appropriate parties and request comments	BSCCo	Appropriate parties	<p>BSCP32/4.1, Application for a Metering Dispensation</p> <p>Additional information as appropriate</p>	Fax /Post /Email
3.1.7	Within 10 WD of 3.1.6	Provide comments	Appropriate parties	BSCCo	Requested comments	Fax /Post /Email

REF	WHEN	ACTION	FROM	TO	INPUT INFORMATION REQUIRED	MEDIUM
3.1.8	At least 6 WD prior to Panel meeting considering the application	Prepare and submit Panel paper for consideration (including, where relevant for a site specific Metering Dispensation application, the ELVA's view on any proposed power transformer and/or cable/line electrical loss adjustments)	BSCCo	Panel	Panel paper	Internal process
3.1.9	At Panel meeting	Consider application and either approve the Metering Dispensation, defer the Metering Dispensation pending more information, or reject the Metering Dispensation. The Panel, in deferring a Metering Dispensation, may seek further consultation as appropriate Notify BSCCo of Panel decision.	Panel	BSCCo	Panel decision	
3.1.10	Within 3 WD of Panel meeting where application is accepted or rejected	Inform Applicant and TAA of Panel decision Update the Metering Dispensations log where appropriate on the Metering Dispensations webpage.	BSCCo BSCCo	TAA, Applicant	BSCP32/4.4, Notification of Panel Ruling on Metering Dispensation Application Upload the public Metering Dispensation details (if approved) to the register of site specific Metering Dispensations, or statement of generic Metering Dispensations.	Fax /Post /Email
3.1.11	Within 10 WD of 3.1.10	Acknowledge receipt and accept Panel determination	Applicant	BSCCo	BSCP32/4.4, Notification of Panel Ruling on Metering Dispensation Application	Fax /Post /Email

2 Withdrawal of a Proposed or Approved Metering Dispensation.

REF	WHEN	ACTION	FROM	TO	INPUT INFORMATION REQUIRED	MEDIUM
-----	------	--------	------	----	----------------------------	--------

REF	WHEN	ACTION	FROM	TO	INPUT INFORMATION REQUIRED	MEDIUM
3.2.1	On or after receipt of Panel decision	Applicant may apply to withdraw provided it wishes to comply with relevant CoPs (this may include a site no longer existing in which case the Metering Dispensation should also be withdrawn)	Applicant	BSCCo	BSCP32/4.5, Application to Withdraw a Metering Dispensation Application form must be signed by a Category R Authorised Person as registered under BSCP38.	Letter /Fax /Email
3.2.2	Within 2WD of 3.2.1	Log withdrawal in the register and confirm receipt	BSCCo	Applicant TAA	BSCP32/4.5, Application to Withdraw a Metering Dispensation	Letter /Fax /Email

DRAFT

3.3 Validation of Power Transformer and Cable/Line Loss Adjustments to be applied to a Metering System

This section applies where the Registrant of a Metering System proposes to apply electrical loss adjustments for power transformers and/or cable or line losses to a Metering System under a site specific Metering Dispensation (see Section 3.1) or proposes to apply relevant electrical loss adjustments to a Metering System where a Metering Dispensation is not required under the relevant Code of Practice.

REF	WHEN	ACTION	FROM	TO	INPUT INFORMATION REQUIRED	MEDIUM
3.3.1	Before submission of application for a site specific Metering Dispensation (see section 3.1), where the Registrant proposes to apply electrical loss adjustments to the Metering System or As required, where a Metering Dispensation is not required under the relevant Code of Practice and where the Registrant proposes to apply relevant electrical loss adjustments to the Metering System	Request manufacturer's information from the owner of the power transformer and/or cable/line between the AMP and the DMP to enable relevant electrical loss adjustments to be calculated	Applicant	Affected parties (e.g. Transmission network owner, LDSO or Customer)	Request for manufacturer's information from the owner of the power transformer and/or cable/line between the AMP and the DMP to enable relevant electrical loss adjustments to be calculated.	Fax / Post / Email
3.3.2	Following 3.3.1	Provide manufacturer's information for the power transformer and/or cable/line between the AMP and the DMP to enable relevant electrical loss adjustments to be calculated	Affected parties (e.g. Transmission System owner, LDSO or Customer)	Applicant	Manufacturer's information from the owner of the power transformer and or cable/line between the AMP and the DMP to enable relevant electrical loss adjustments to be calculated	Fax / Post / Email

REF	WHEN	ACTION	FROM	TO	INPUT INFORMATION REQUIRED	MEDIUM
3.3.3	Following 3.3.2	Calculate relevant electrical loss adjustments for the power transformer and/or cable/line between the AMP and the DMP	Applicant			Internal process
3.3.4	As required but at the same time as 3.1.2 or At least 30WD before the EFD of the Metering System	Submit application for a site specific Metering Dispensation in accordance with Section 3.1 including information on the power transformer and/or cable/line to enable relevant electrical loss adjustments to be validated and the proposed electrical loss adjustments Submit the relevant information required (as set out in Part D1 of BSCP32/4.1) including Site Name, relevant Circuit Identifier(s), MSID(s), Meter Type(s), Meter Serial Number(s) and (if adjustments are to be applied using this method) Aggregation Rule(s)	Applicant	BSCCo	BSCP32/4.1, Application for a Metering Dispensation For a site specific Metering Dispensation application where the AMP is not at the DMP, include the proposed electrical loss adjustments and information on the power transformer and/or cable/line between the AMP and the DMP to enable these loss adjustments to be validated. Application forms must be signed by a Category R Authorised Person as registered under BSCP38, or include their password and be sent from the Authorised Person's email address Relevant information required (as set out in Part D1 of BSCP32/4.1) including Site Name, relevant Circuit Identifier(s), MSID(s), Meter Type(s), Meter Serial Number(s) and (if adjustments are to be applied using this method) Aggregation Rule(s)	Fax / Post / Email

REF	WHEN	ACTION	FROM	TO	INPUT INFORMATION REQUIRED	MEDIUM
3.3.5	Within 2 WD of 3.3.4	<p>Check application for validity and completeness with regard to the proposed electrical loss adjustments and information on the power transformer and/or cable/line between the AMP and the DMP to enable these loss adjustments to be validated. Receipt acknowledgement covered by 3.1.3.</p> <p>or</p> <p>Check for validity and completeness with regard to relevant information required (as set out in Part D1 of BSCP32/4.1) including Site Name, relevant Circuit Identifier(s), MSID(s), Meter Type(s), Meter Serial Number(s) and (if adjustments are to be applied using this method) Aggregation Rule(s) and acknowledge receipt</p>	BSCCo	Applicant	<p>BSCP32/4.1 Application for a Metering Dispensation</p> <p>For a site specific Metering Dispensation application where the AMP is not at the DMP, include the proposed electrical loss adjustments and information on the power transformer and/or cable/line between the AMP and the DMP to enable these loss adjustments to be validated.</p> <p>or</p> <p>Relevant information required (as set out in Part D1 of BSCP32/4.1) including Site Name, relevant Circuit Identifier(s), MSID(s), Meter Type(s), Meter Serial Number(s) and (if adjustments are to be applied using this method) Aggregation Rule(s)</p> <p>Acknowledgment of receipt</p>	<p>Internal process</p> <p>Internal process</p> <p>Fax / Post / Email</p>
3.3.6	Within 5 WD of 3.3.5, where appropriate	Where additional information or clarification is required for a determination to be reached as to the validity of the proposed electrical loss adjustments, request such information from the Applicant	BSCCo	Applicant	Request for specific information or clarification	Fax / Post / Email
3.3.7	As required (bearing in mind time required to apply validated electrical loss adjustments to the Metering System before the Metering System EFD)	If request for additional information or clarification is received, provide requested additional information or clarification as agreed between the BSCCo and the Applicant.	Applicant	BSCCo	Requested additional information or clarification	Fax / Post / Email

REF	WHEN	ACTION	FROM	TO	INPUT INFORMATION REQUIRED	MEDIUM
3.3.8	Within 2 WD of 3.3.5 or 3.3.7 (as appropriate)	Request ELVA validates proposed electrical loss adjustments	BSCCo	ELVA	<p>Request to validate proposed electrical loss adjustments</p> <p>BSCP32/4.1, Application for a Metering Dispensation</p> <p>Including the proposed electrical loss adjustments and information on the power transformer and/or cable/line between the AMP and the DMP to enable these loss adjustments to be validated.</p> <p>or</p> <p>Relevant information required (as set out in Part D1 of BSCP32/4.1) including Site Name, Circuit Identifier, MSID(s), Meter Type(s), Meter Serial Number(s) and (if adjustments are to be applied using this method) Aggregation Rule(s) and any Additional information, as appropriate</p>	Fax /Post / Email

REF	WHEN	ACTION	FROM	TO	INPUT INFORMATION REQUIRED	MEDIUM
3.3.9	Within 10WD of 3.3.8	Validate and provide confirmation that the proposed electrical loss adjustments are suitable. Any requests by the ELVA for further information or clarification from the Applicant on the proposed electrical loss adjustments shall be dealt with via BSCCo	ELVA	BSCCo	Requested confirmation that the proposed electrical loss adjustments are suitable	Fax /Post / Email
3.3.10	Within 2 WD of receipt of confirmation from ELVA that the proposed electrical loss adjustments are suitable	Provide confirmation from ELVA that the proposed electrical loss adjustments are suitable ² to Applicant.	BSCCo	Applicant	ELVA confirmation that the proposed electrical loss adjustments are suitable	Fax /Post / Email

² Where the ELVA considers the proposed electrical loss adjustments as not suitable, the applicant may withdraw the application, propose new electrical loss adjustments or ask the BSCCo to proceed with the application and provide additional justification for the proposed electrical loss adjustments to support its use for the Metering System.

4 Appendices

4.1 Application for a Metering Dispensation

Form, BSCP32/4.1 should be used by the Applicant when applying for a Metering Dispensation. It is also used by the BSCCo to acknowledge receipt of the application.

4.2 Form BSCP32/4.2 is no longer used.

4.3 Form BSCP32/4.3 is no longer used.

4.4 Notification of Panel Ruling on Metering Dispensation Application

Form, BSCP32/4.4 should be used by the BSCCo to communicate the Panel decision with regard to a particular Metering Dispensation application to the TAA and the Applicant. It should also be used by the Applicant when acknowledging and accepting the Panel determination.

4.5 Application to Withdraw a Metering Dispensation

Form BSCP32/4.5 should be used by the Applicant when withdrawing a proposed or approved Metering Dispensation. Such a withdrawal implies that the Applicant will now meet the requirements of the Code of Practice from which he may previously have held a Metering Dispensation. The BSCCo will also use the form to acknowledge receipt of the withdrawal both to the Applicant and to the TAA.

4.6 Form BSCP32/4.6 is no longer used.

4.7 Forms

All the forms for use in this BSCP are shown below.

BSCP32/4.1 Application for a Metering Dispensation

Part A – Applicant Details

To: BSCCo		Date Sent: _____
From: Requesting Applicant Details		
Name of Sender: _____		
Contact email address: _____		
Contact Tel. No. _____	Contact Fax. No. _____	
Name of Applicant Company: _____		
Address: _____ _____ _____		
Post Code: _____	Our Ref: _____	
Name of Authorised Signatory: _____		
Authorised Signature: _____	Password: _____	

Confidentiality:

Does any part of this application form contain confidential information?

Request for Confidentiality **YES/NO***

**Delete as applicable*

If 'YES', please state the parts of the application form that are considered confidential, including justification below. Information that is considered confidential:

Reasons for requesting confidentiality:
.....

number, site name, expiry date (if any) and BSC Panel determinations will routinely be made available in the public domain unless the applicant informs BSCCo otherwise at the time of application

BSCP32/4.1 Application for a Metering Dispensation (Cont.)**Part B - Affected Party Details**Number of Affected parties _____³

Contact Name at Affected party:	
Contact email address:	
Contact Tel. No.	Contact Tel. No.
Company Name of Affected party:	
Address:	
Post Code:	

Contact Name at Affected party:	
Contact email address:	
Contact Tel. No.	Contact Tel. No.
Company Name of Affected party:	
Address:	
Post Code:	

³ For more than one Affected party, Part B should be completed for each, using additional copies of Part B as required.

Contact Name at Affected party:	
Contact email address:	
Contact Tel. No.	Contact Tel. No.
Company Name of Affected party:	
Address:	
Post Code:	

DRAFT

BSCP32/4.1 Application for a Metering Dispensation (Cont.)**Part C – Reason for Application**

If the application is an extension or update for an existing Metering Dispensation, enter existing ref: D/.....

Site Specific / Generic* *Delete as applicable.

Describe why you require a Metering Dispensation. Include any steps you propose to limit the impact on Settlement and other Registrants:

Period of Metering Dispensation required

Lifetime / Temporary* *Delete as applicable.

If temporary, indicate for how long the Metering Dispensation is required.

Provide justified reasoning for the period of Metering Dispensation requested in the box below:

Rationale for duration of Metering Dispensation:

Part D1 - Loss Adjustments for Power Transformer and/or Cable/Line Losses

Where loss adjustments are proposed and applied (or are to be applied) to the Metering System for power transformer and/or cable/line losses, provide the following information:

Describe how do you propose to correct the Metering System to account for the losses of this power transformer?

In order to validate the loss adjustments applied (or to be applied) to the Metering System please provide the following information together with supporting data (e.g. power transformer test certificates):

What are the iron losses for this power transformer?

What are the copper losses for this power transformer?

Are there any other losses that have been taken into account? Yes/No*. If Yes what are they?

Demonstrate how these elements of loss have been used in the corrections to the Metering System.

*Delete as applicable.

Describe how do you propose to correct the Metering System to account for the losses of the power cable/line?

In order to validate the loss adjustments applied (or to be applied) to the Metering System please provide the following information together with supporting data (e.g. cable/line manufacturer's data sheet):

What is the type of power cable/line?

What is the length of this power cable/line?

What is the DC resistance of this power cable/line?

What is the impedance of this power cable/line?

What is the capacitance of this power cable/line?

Are there any other losses that have been taken into account? Yes/No*. If Yes what are they?

Demonstrate how these elements of loss have been used in the corrections to the Metering System.

*Delete as applicable.

DRAFT

Materiality

Please complete the following:

What is the cost of providing compliant Metering Equipment?	What does this cost entail?
What is the cost of the proposed solution?	What does this cost entail?
What is the impact to Settlement of your proposed solution?	Why?
What is the impact to other Registrants of your proposed solution?	Why?

Site Details (for Site Specific Metering Dispensation)

Site Name:	
Site Address:	
MSID(s):	
Registered in: CMRS / SMRS*: *Delete as applicable.	
For SMRS, please advise of SMRA in space provided.	

Manufacturer Details (for Generic Metering Dispensation)

Manufacturer Name:	
Metering Equipment Details:	

BSCP32/4.1 Application for a Metering Dispensation (Cont.)
Part D - Technical Details
Code of Practice details

Metering Dispensation against Code of Practice*	
Issue of Code of Practice*:	
Capacity of Metering Circuits/Site Maximum Demand (MW/MVA):	
(Proposed) Commissioning Date of Metering:	
Accuracy at Defined Metering Point:	
Accuracy of Proposed Solution (including loss adjustments):	
Outstanding non-compliances on Metering Systems:	
Deviations from the Code of Practice (reference to appropriate clause):	

* insert Code of Practice number and issue

Any Other Technical Information

--

Declaration

We declare that other than as set out above we are in all other respects, in compliance with the requirements of the relevant Code of Practice and the BSC. A schematic is attached to this application for clarification of the metering points involved.

Signature: *Date:*

Password:

Duly authorised for and on behalf of Applicant Company

Confirmation of Receipt and Reference

The BSCCo acknowledges receipt of this document and has assigned the reference number as indicated on the first page.

Signature: *Date:*

Duly authorised for and on behalf of the BSCCo

DRAFT

BSCP32/4.2 **This form is no longer used and is intentionally left blank**

BSCP32/4.3 **This form is no longer used and is intentionally left blank**

DRAFT

BSCP32/4.4 Notification of Panel Ruling on Metering Dispensation Application

Reference No.:

From: Balancing and Settlement Code Company

To: *Applicant Company:*
Address:

Contact Name:

Telephone Number:

Cc: TAA

Metering Dispensation number:

Your application to the Panel with regard to the above Metering Dispensation from Code of Practice _____ was considered at the Panel meeting of _____ and the Panel have:

Agreed to the application*

Dismissed the application*

Referred the application for more information*

* *delete as applicable*

Other information

.....
.....
.....
.....
.....

Signature: *Date:*

Duly authorised for and on behalf of the Panel

The above Metering Dispensation and any conditions have been accepted by the Applicant Company.

Signature: *Date:*

Duly authorised for and on behalf of the Applicant Company

BSCP32/4.5 Application to Withdraw a Metering Dispensation

To: BSCCo

Cc: TAA

Reference No.:

Company Details

Name of Applicant Company:

Address:

.....

.....

Contact Name:

Telephone Number:

Declaration

The above named Registrant wishes to inform the Panel that, in respect of the above Metering Dispensation, it now intends to comply fully with the requirements of Code of Practice _____ and therefore wishes to withdraw either:

a) The approved Metering Dispensation;

or

b) The proposed Metering Dispensation.

Signature:

Date:

Password:

Duly authorised for and on behalf of Applicant Company

The above Metering Dispensation withdrawal has been received by the BSCCo.

Signature:

Date:

Duly authorised for and on behalf of BSCCo

BSCP32/4.6

This form is no longer used and is intentionally left blank

DRAFT