



Change Proposal Circular

CPC00696: Impact Assessment of CP1346

Responses for CP1346 'Proving tests shall not be based on verbal Meter Technical Details'



Any Questions

If you have any queries,
please contact:

CCC@elexon.co.uk

Or contact:

**BSCP40 Change
Process Task Leader
020 7380 1435**

Summary of Responses

Organisation	Capacity in which Organisation operates in	Agree?	Impacted?	Days needed to implement
EDF Energy	Supplier, NHH Agent and HH MOP	Yes	Yes	30
UK Power Networks: London Power Networks plc, South Eastern Power Networks plc, Eastern Power Networks plc, UK Power Networks (IDNO) Ltd	Distributor	Neutral	Yes	-
TMA Data Management	HHDC, HHDA, NHHDC and NHHDA	Yes	No	-
IBM (for and on behalf of Scottish Power)	ScottishPower Energy Management Ltd. ScottishPower Generation Ltd. ScottishPower Energy Retail Ltd. ScottishPower Manweb plc. ScottishPower Distribution Ltd.	Yes	No	-

CPC00696

28 April 2011

Version 1.0

Page

© ELEXON Limited 2011

Detailed Impact Assessment Responses			
Organisation	Agree?	Impacted?	Comments
EDF Energy	Yes	Yes	Agree change comment - It is a simple change to address a known issue that we feel has negligible negative consequences. For which role is your organisation impacted? CVA MOA Please state what the impact is - Potential additional operational / administrative work for some circumstances of proving tests. Lead time comment - A lead time of 30 days would be sufficient to provide update / training to affected staff Associated costs comment – Negligible Any other comments - This change provides a sensible way forward in addressing this issue and as such we support its implementation.
UK Power Networks	Neutral	Yes	For which role is your organisation impacted? Distributor Please state what the impact is – Managing MTDs Would implementation in the proposed Release have an adverse impact on your organisation? This change will clearly make more accurate the process for managing MTDs but it will also slow it down and increase costs - MOAs may have to make multiple site visits. Associated costs comment – This would fall under our MOA remit and therefore it would be a question on further visits equal further costs. The full extent of this cost would be too early to tell.
TMA Data Management	Yes	No	Agree change comment – A proving test should never be completed on verbal MTD, the point of a proving test is to ensure that the details held on the system, provided through the appropriate channels, match the MTD installed.
IBM (for and on behalf of Scottish Power)	Yes	No	-

No comments received on the redlined text.



About Severity Codes

H (High):
Prejudices document's conclusions, recommendations or fitness for purpose.

M (Medium):
Matter of substance, but not high.

L (Low):
Minor error but document's intention is clear.

CPC00696

28 April 2011

Version

Page 2 of 2

© ELEXON Limited 2011