

## Change Proposal – F40/01 (Page 1 of 2)

CP No: 940

### Title: Clarification of Proving Test Requirements in BSCP02 and BSCP20

#### Description of Change:

CP821 'Improvements to Central Volume Allocation Proving Test Requirements' which will be implemented in June 2003 introduces a new BSCP (BSCP02 'Proving Test Requirements for Central Volume Allocation Metering Systems') and delivers associated amendments to BSCP20 'Registration of Metering Systems for Central Volume Allocation'. Following review of the two BSCPs, several areas have been identified where clarifications would be useful. It was felt that these amendments were too material to be included in the drafting for CP821, and so this Change Proposal is being raised to deliver these changes.

#### Proposed Solutions:

##### Clarifications to BSCP02:

###### Section 1.3

In section 1.1.1 it states that the MOA should consult with the CDCA and / or BSCCo (ELEXON), as appropriate, to agree the scope of testing required. In section 1.2 (c) it states that simplified commissioning and Proving Tests may be employed following subsequent work on a Metering System, with agreement of the CDCA / BSCCo provided the integrity of Settlement data can be shown to be maintained.

In both cases BSCCo is involved in the process, therefore BSCCo should be included in section 1.3 as a main user.

###### Sections 3.1.1, 3.2.1, 3.4.2 and 3.6.2 (Action column)

There is no obligation in Code of Practice Four for the MOA to advise the CDCA of the date when commissioning will be completed. Remove the reference to CoP 4.

###### Section 5.3 (Proving Test Required columns)

The term 'simple dial up' is not defined and should be defined as:

'a communication check carried out by the CDCA to confirm that the Instation can collect data from an Outstation. No further validation of this data is required.'

##### Clarifications to BSCP20:

###### Page 13, ref 3.1.13

Metering systems are installed and commissioned in accordance with Code of Practice Four, not BSCP02. However this ref 3.1.13 should be removed, as it is now an integral part of BSCP02 and not BSCP20.

###### Page 36, Form BSCP20/4.4

Remove this form, it is not required for BSCP20, it is now contained in BSCP02 (form BSCP02/4.4).

#### Justification for Change:

*These changes will serve to minimise confusion amongst participants with regards to Proving Test Requirements and will complement the changes delivered by CP821.*

<p align="center"><b>Change Proposal – F40/01 (Page 2 of 2)</b></p>	<p>CP No:</p>
<p><b>Other Configurable Items Potentially Affected by Proposed Solutions:</b></p> <p>None</p>	
<p><b>Impact on Core Industry Documents:</b></p> <p>None</p>	
<p><b>Related Changes and/or Projects:</b></p> <p>CP821 CVA June 03 Systems Release</p>	
<p><b><i>Originator's Details:</i></b></p> <p><b><i>BCA Name</i></b></p> <p><b><i>Organisation</i></b>                    <b><i>ELEXON</i></b></p> <p><b><i>Email Address</i></b></p> <p><b><i>Date</i></b>                                    <b><i>05 March 2003</i></b></p>	
<p>Attachments: N</p>	