

Change Proposal – F40/01 (Page 1 of 2)	CP No: 841 <i>(mandatory by BSCCo)</i>
Title <i>(mandatory by originator)</i> Substituted metered data in the CDCA I012 'Raw Metered Data Report'	
Description of Change <i>(mandatory by originator)</i> The CDCA I012 'Raw Metered Data Report' is intended to provide each Metering System Registrant with a record of the metered data uploaded from each Metering System on a daily basis. As the name of the report implies it is intended to provide the data in its raw format and will indicate its status: A - 'Valid Metered Data', B - 'Invalid Metered Data' and C - 'Unavailable Metered Data'. Currently CDCA I014 report also includes substituted metered data i.e. where the nominated Primary Outstation main channel (the settlement channel) metered data is invalid, or missing, and the metered data from the equivalent channel in the nominated Secondary Outstation is valid the CDCA substitutes the equivalent Secondary Outstation metered data into the Primary Outstation channel. As the substituted data appears in the Primary Outstation channel as 'valid meter data' it is interpreted as though the metered data had been uploaded directly from the Metering System. It should be appreciated that because of compliant variances in outstation timing the Secondary Outstation data, which is classified as 'valid metered data' can be different in value to the metered data that would have been presented as uploaded from the Primary Outstation.	
Proposed Solution(s) <i>(mandatory by originator)</i> The CDCA software will be changed to stop any substituted data being included in the CDCA I012 'Raw Metered Data Report'. The CDCA I037 'Estimated Data Notification' report, that is being changed as part of the CDCA Improvement Project, will include substituted data via the use of new reason codes. The revised codes and description include: J) Generation – Main meter data missing, or incorrect, in Primary Outstation, Secondary Outstation main meter data available – substituted from Secondary Main L) Demand – Primary Main meter data missing, or incorrect, Secondary Outstation Main meter data available – substituted from Secondary Main Where the estimation is carried out using substituted metered data from the nominated Secondary Outstation active main channel the CDCA will not require agreement from the Registrant (see ELEXON Circular EL00267 for further information). Therefore where substitutions from equivalent Secondary Outstation channels are used, the CDCA I037s will be sent for information only and will not require a response confirming agreement.	

Justification for Change (<i>mandatory by originator</i>) As the use of this substituted metered data, in the CDCA I012 'Raw Metered Data Report' is misleading to Metering System Registrants it is proposed to rectify this as soon as possible under the Change Management Process detailed in BSCP 40.	
Change Proposal – F40/01 (Page 2 of 2)	CP No: 841 (<i>mandatory by BSCCo</i>)
Other Configurable Items Potentially Affected by Proposed Solution(s) (<i>optional by BSCCo</i>)	
Impact on Core Industry Documents (<i>optional by originator</i>)	
Related Changes and/or Projects (<i>mandatory by BSCCo</i>)	
Originator's Details: BCA Name Organisation ELEXON Email Address Date 30th July 2002	
Attachments: N	