

Change Proposal – F40/01 (Page 1 of 3)	CP No: 779 <i>(mandatory by BSCCo)</i>
Title <i>(mandatory by originator)</i> Clarification to the proving of Half Hourly Metering Systems in BSCP502.	
Description of Change <i>(mandatory by originator)</i> A clarification is required to the proving rules detailed in Appendix 4.6 of BSCP502 'Half Hourly Data Collection of SVA Metering Systems Registered in SMRS' version 4.0.	
Proposed Solution(s) <i>(mandatory by originator)</i> In section 4.6.1 of Appendix 4.6 BSCP502, which explains when proving tests should be carried out on Half Hourly Metering Systems, the fourth bullet should be amended to read: <ul style="list-style-type: none"> ▪ 'Following a concurrent Change of Supplier and change of HHDC and where there has been manual intervention of the MTD;' The bold text highlights the new text to be included.	
Justification for Change <i>(mandatory by originator)</i> Proving tests are required to be initiated following concurrent Changes of Supplier and HHDC when the Meter Technical Details (MTD) have been manually intervened in some way; though this is not reflected in BSCP502. This is the same condition as that which applies to single change of Half Hourly Data Collector (refer to bullet point 2 of section 4.6.1 of Appendix 4.6). The circumstance in which a proving test should be initiated should apply equally whether or not there is a single change of Half Hourly Data Collector or a coincident change of Supplier and Half Hourly Data Collector.	
Other Configurable Items Potentially Affected by Proposed Solution(s) <i>(optional by BSCCo)</i> None.	
Impact on Core Industry Documents <i>(optional by originator)</i> None.	
Related Changes and/or Projects <i>(mandatory by BSCCo)</i> None.	

Change Proposal – F40/01 (Page 2 of 2)	CP No: <i>(mandatory by BSCCo)</i>
Originator's Details: BCA Name: <i>Ceri Hughes</i> Organisation: ELEXON Email Address: <i>ceri.hughes@elexon.co.uk</i> Date: <i>08/04/2002</i>	
Attachments: No	