

### Reason Codes

The following list of Reason Codes will be used by the CDCA to identify the reason for requiring a Data Estimation or Substitution and the source of the data used for this purpose.

The CDCA system will continue to support redundant Estimation Method codes for historical data.

Method Code	Reason for Estimation/Substitution	Method Used
A	Generation: Main meter data missing or incorrect in Primary and Secondary Outstations, Check meter data available	Copied from Primary Check
J	Generation: Main meter data missing or incorrect in Primary Outstation, Secondary Outstation Main meter available	Substituted from Secondary Main
K	Generation: Main and Check meter data missing or incorrect in Primary and Secondary Outstations, data estimated to zero awaiting confirmation of generation	Manual Estimate to zero
D	Demand: Main meter failed, Check meter data available	Copied from Primary Check
L	Demand: Primary Main meter missing or incorrect, Secondary Outstation Main meter data available	Substituted from Secondary Main
E	Demand: Main meter failed, Check meter not fully functional, but Check meter register advance available	Profile using Meter Reading Estimation Tool
M	Demand: Main meter failed, data copied from suitable settlement day	Manual Estimate
I	Demand: Main meter failed, check meter not fully functional, Check meter register advance <b>NOT</b> available	Profile using Trend
N	Validation Failure: Main data deemed correct	Quality Promoted
U	Used parties own readings	Manual Estimate
X	Used different estimation method	Manual Estimate