

**Redlined BSCP514 for CP1411 'Remove exemption from Proving Tests for Code of Practice 10 Metering Systems'**

This CP proposes changes to BSCP514 section 8.3.1.

We have redlined these changes against Version 26.0.

## 8.3 Proving of Half Hourly Metering Systems

### 8.3.1 Reasons for a Proving Test

A proving test shall be carried out on both main and check MS and shall be carried out in the following circumstances:

- As a result of new connection or Registration Transfers from CMRS to SMRS;
- Following a change of HHDC appointment but only in the event that the MTD was manually intervened;
- Following a change of HHMOA appointment but only in the event that the MTD was manually intervened;
- Following a concurrent Change of Supplier and HHDC but only in the event that the MTD was manually intervened;
- When a MS is reconfigured / replaced;
- Following a change of Measurement Class from NHH to HH;
- When there is a Key field change (refer to Appendix 8.2);
- Where there has been a key field change (refer to Appendix 8.2) whilst a site has been de-energised and the MS becomes energised;
- Whenever a shared SVA MS arrangement is carried out; and
- Where a feeder is energised for the first time.

‘Manually intervened (with regard to proving tests)’ means that MTD have been entered, re-entered or changed in a software system manually i.e. the data has not been automatically entered into systems via receipt of a data flow.

~~MS assigned to Code of Practice 10 are exempt from proving tests.~~