

Redlined BSCP514 for CP1411 'Remove exemption from Proving Tests for Code of Practice 10 Metering Systems'

This CP proposes changes to BSCP514 section 8.3.1.

We have redlined these changes against Version 26.0.

8.3 Proving of Half Hourly Metering Systems

8.3.1 Reasons for a Proving Test

A proving test shall be carried out on both main and check MS and shall be carried out in the following circumstances:

- As a result of new connection or Registration Transfers from CMRS to SMRS;
- Following a change of HHDC appointment but only in the event that the MTD was manually intervened;
- Following a change of HHMOA appointment but only in the event that the MTD was manually intervened;
- Following a concurrent Change of Supplier and HHDC but only in the event that the MTD was manually intervened;
- When a MS is reconfigured / replaced;
- Following a change of Measurement Class from NHH to HH;
- When there is a Key field change (refer to Appendix 8.2);
- Where there has been a key field change (refer to Appendix 8.2) whilst a site has been de-energised and the MS becomes energised;
- Whenever a shared SVA MS arrangement is carried out; and
- Where a feeder is energised for the first time.

‘Manually intervened (with regard to proving tests)’ means that MTD have been entered, re-entered or changed in a software system manually i.e. the data has not been automatically entered into systems via receipt of a data flow.

~~MS assigned to Code of Practice 10 are exempt from proving tests.~~