

Redlined BSCP514 for P302 'Improving the Change of Supplier Meter read process for smart Meters'.

P302 Proposed Modification and P302 Alternative Modification propose identical changes to BSCP514 sections 1.6 and 6.2.4.

We have redlined these changes against Version 27.0.

1.6 Acronyms and Definitions

1.6.1 Acronyms

The terms used in this BSCP are defined as follows.

BSC	Balancing and Settlement Code
BSCP	BSC Procedure
CMRS	Central Meter Registration Service
CoMC	Change of Measurement Class
CoP	Code of Practice
CoS	Change of Supplier
CT	Current Transformer
CVA	Central Volume Allocation
DC	Data Collector
<u>DCC</u>	<u>Data and Communications Company</u>
DTC	Data Transfer Catalogue
DTN	Data Transfer Network
ECOES	Electricity Central Online Enquiry Service
EFSD {REGI}	Effective From Settlement Date {Registration}
ETSD {MOA}	Effective to Settlement Day {Meter Operator Agent}
HH	Half Hourly
HHDA	Half Hourly Data Aggregator
HHDC	Half Hourly Data Collector
HHMOA	Half Hourly Meter Operator Agent
HHU	Hand Held Unit
Id	Identifier
kV	Kilo Volt
kWh	Kilowatt hour
LDSO	Licensed Distribution System Operator
LLF	Line Loss Factor
MAP	Meter Asset Provider
MAR	Meter Advance Reconciliation
MDD	Market Domain Data
MDDM	Market Domain Data Manager
ME	Metering Equipment
MOA	Meter Operator Agent
MS	Metering System
MSID	Metering System Identifier
MTD	Meter Technical Details
NHH	Non-Half Hourly
NHHDC	Non-Half Hourly Data Collector
NHHMOA	Non-Half Hourly Meter Operator Agent

PSL	Party Service Line
Ref	Reference
SFIC	Systems Fault Information Centre
SMRS	Supplier Meter Registration System
SSD	Supply Start Date
SVA	Supplier Volume Allocation
SVAA	Supplier Volume Allocation Agent
UMetS	Urgent Metering Service
UTC	Co-ordinated Universal Time
VT	Voltage Transformer
WD	Working Day

6.2.4 Concurrent change of Supplier and NHHMOA ~~(No Change to Metering System)~~

REF	WHEN	ACTION	FROM	TO	INFORMATION REQUIRED	METHOD
6.2.4.1	As required	Send appointment. The Supplier will notify the new NHHMOA if the Metering System has a smart Meter using the Contract Reference (or by other means, as agreed). <u>The Supplier will notify the New NHHMOA if the Metering System has a DCC-serviced smart Meter.</u>	New Supplier	New NHHMOA	D0155 Notification of New Meter Operator or Data Collector Appointment and Terms.	Electronic or other method, as agreed.
6.2.4.2	If appointment rejected and within 2 WD of 6.2.4.1	Send notification of rejection of appointment including the reason why the request has been rejected.	New NHHMOA	New Supplier	D0261 Rejection of Agent Appointment. (Go to 6.2.4.1 if required)	Electronic or other method, as agreed.
6.2.4.3	If appointment accepted and within 2 WD of 6.2.4.1	Send notification of acceptance of appointment.	New NHHMOA	New Supplier	D0011 Agreement of Contractual Terms.	Electronic or other method, as agreed.
6.2.4.4	Within 5 WD of notification from SMRS or by last date of Supplier Appointment	Send notification of termination of appointment.	Current Supplier	Current NHHMOA	D0151 Termination of Appointment or Contract by Supplier.	Electronic or other method, as agreed.
6.2.4.5	If de-appointment accepted and within 5 WD of 6.2.4.4	Send notification of de-appointment.	Current NHHMOA	MAP	D0303 Notification of Meter Operator, Supplier and Metering Assets installed/removed by the MOP to the MAP.	Electronic or other method, as agreed.
6.2.4.6	If de-appointment rejected and within 5 WD of 6.2.4.4	Send notification of rejection of de-appointment.	Current NHHMOA	Current Supplier	Note that rejection of de-appointment shall only occur if the current NHHMOA has a contract with the customer.	Electronic or other method, as agreed.

REF	WHEN	ACTION	FROM	TO	INFORMATION REQUIRED	METHOD
6.2.4.7	On appointment of NHHMOA and within 1 WD of 6.2.4.3 ¹	Send notification of NHHDC and current NHHMOA.	New Supplier	New NHHMOA / NHHDC	D0148 Notification of Change to Other Parties. D0302 Notification of Customer Details.	Electronic or other method, as agreed.
6.2.4.8	Within 1 WD of 6.2.4.6	Request MTD.	New NHHMOA	Current NHHMOA	D0170 Request for Metering System Related Details.	Electronic or other method, as agreed.
6.2.4.9	Within 2 WD of 6.2.4.8 For those Meters defined in Appendix 9.3, the D0149, D0150 and D0313 may be sent as late as SSD – 1 WD to maintain security.	Send MTD.	Current NHHMOA Error! Bookmark not defined. ³⁰	New NHHMOA Error! Bookmark not defined. ⁹	D0149 Notification of Mapping Details. D0150 Non Half Hourly Meter Technical Details. Error! Bookmark not defined. ⁵⁰ D0313 Auxiliary Meter Technical Details (in accordance with Appendix 9.3)	Electronic or other method, as agreed.
<u>For Metering Systems which are not serviced by the DCC</u>						
6.2.4.10	Within 1 WD of 6.2.4.9	Send MTD.	New NHHMOA	New Supplier / NHHDC / LDSO New Supplier / NHHDC	D0149 Notification of Mapping Details. D0150 Non Half Hourly Meter Technical Details. Error! Bookmark not defined. ⁵⁰ D0313 Auxiliary Meter Technical Details (in accordance with Appendix 9.3)	Electronic or other method, as agreed.
<u>For Metering Systems which are serviced by the DCC</u>						

¹ Note that if there is also a concurrent Change of NHHDC, the New Supplier shall send the D0148 once the D0011 from both the MOA and the NHHDC has been received and within 5 WD of the receipt of the latter D0011.

REF	WHEN	ACTION	FROM	TO	INFORMATION REQUIRED	METHOD
6.2.4.11	As soon as possible after midnight UTC on the SSD	Configure Meter²	New Supplier			
6.2.4.12	Within 1 WD of 6.2.4.11	Send Smart Meter Configuration Details	New Supplier	New NHHMOA	D0367 Smart Meter Configuration Details (or alternative method, as agreed bilaterally between the Supplier and NHHMOA)	Electronic or other method, as agreed
6.2.4.13	If the new Supplier has been unable to communicate with the smart Meter by SSD+4WD	Notify the new NHHMOA that the process for non DCC-serviced NHH Metering Systems should be followed	New Supplier	New NHHMOA	D0155 Notification of New Meter Operator or Data Collector Appointment and Terms	Electronic or other method, as agreed
6.2.4.14	Within 2WD of 6.2.4.13	Confirm reversion to process for non DCC-serviced NHH Metering Systems Proceed from step 6.2.4.10.	New NHHMOA	New Supplier	D0011 Agreement of Contractual Terms	Electronic or other method, as agreed
6.2.4.15	Where 6.2.4.13 does not apply, within 1 WD of the later of 6.2.4.9 and 6.2.4.12	Send revised MTD	New NHHMOA	New Supplier / NHHDC / LDSO	D0149 Notification of Mapping Details. D0150 Non Half Hourly Meter Technical Details. Error! Bookmark not defined. ⁵⁰	Electronic or other method, as agreed
For all NHH Metering Systems						

² [If the new Supplier is unable to configure the Meter until after the SSD, but is able to do so by SSD+5WD, for example due to a communications failure, the new Supplier will re-date any SSC change \(and associated\) readings to the SSD. If the new Supplier is unable to configure the Meter until after SSD+5WD, the new Supplier will use the change of SSC process in BSCP504 section 3.3.6 and will adopt the old Supplier's SSC for the intervening period.](#)

REF	WHEN	ACTION	FROM	TO	INFORMATION REQUIRED	METHOD
6.2.4.1 46	Optional, but if followed then within 10 WD of 6.2.4.10 <u>or</u> <u>6.2.4.15 as appropriate.</u>	Send the relevant Meter information changes.	New NHHMOA	ECOES	D0312 Notification of Meter Information to ECOES.	Electronic or other method, as agreed.