

Redlined BSCP514 for CP1429 'Proving Test timescales'.

This CP proposes changes to BSCP514 section 8.3.5.

We have redlined these changes against Version 27.0.

8.3.5 Proving Test / Re-Test Timescales

Proving Test Timescales

A proving test may be undertaken prior to the appointment of the HHDC and / or HHMOA in the SMRS so long as there is agreement between the Supplier, HHMOA, HHDC and the customer.

The timescale for carrying out the proving test shall vary depending on the Code of Practice that the MS is assigned to.

It is not necessary that all the steps of the relevant processes are carried out on the same day; the requirement is that the proving test in its entirety is completed by the timescale specified below and subject to the exceptions listed below. The maximum timescale between the initiation of a proving test as a result of the circumstances in 8.3.1 and the successful completion of the proving test by the HHMOA (by sending the D0214 Confirmation of Proving Tests) to the HHDC is listed below for each CoP.

Re-Test Timescales

Where the proving test has failed, the HHMOA shall initiate a re-test and the HHMOA and HHDC should ensure wherever possible that the timescale is the same as for the original proving test.

Timescales

| Code of Practice | WDs to Complete Proving Test ¹ | WDs to Complete Re-Test | Total |
|------------------|---|-------------------------|-----------|
| One | 5 | 5 | 10 |
| Two | 5 | 5 | 10 |
| Three | 10 | 10 | 20 |
| Five | 15 | 15 | 30 |
| <u>Ten</u> | <u>15</u> | <u>15</u> | <u>30</u> |

In the event that timescales are exceeded and the proving test is not completed, the process shall proceed to completion and an audit trail will be maintained by Supplier Agents in order to explain the delay.

¹ The starting date for this time is either the Date of Meter Installation, the Date of Commissioning, the Effective From Date of the Meter, the Effective Date of a Change of Agent as described in Section 8.3.1, or the date when a Metering System becomes energised where there has been a key field change whilst the Metering System was de-energised, whichever is the later.